



PSB Singapore

CERTIFICATE OF CONFORMITY

Product Listing Scheme* : **Class 2**

This Certificate is issued to

SUPERLON WORLDWIDE SDN BHD
Lot 2736 Jalan Raja Nong
41200 Klang
Selangor
Malaysia

FOR

Product: Thermal Insulation Material
Brand: Superlon
Model: Superlon
Country of Origin: Malaysia
Product Details: Density: 60kg/m³
NBR Nitrile Rubber Sheet
Tested with the smooth face exposed to heat

which has complied with the requirements of the scheme and based on the following:

Standard(s)

BS 476 Part 6: 1989 + A1: 2009
BS 476 Part 7: 1997

Test Report(s)

PSB Test no. 7191008382-MEC11/G-YWA &
7191008383-MEC11/H-LGJ
(Rating: Class "0")

Vice-President (Certification Department)
TÜV SÜD PSB

Certificate No:	Date of Original Issue:	Date of Last Revision:	Date of Expiry:
012676	09/09/2011	-	08/09/2014



* All products listed under Class 1A/1B must have this mark affixed / printed on them. Failure to comply with this requirement may result in revocation of this certificate.

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the Product Listing Scheme. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv-sud-psb.com.

PSB 12/07.02

ZERTIFIKAT ◆ CERTIFICATE ◆ CERTIFICADO ◆ CERTIFICAT ◆ CERTIFIKAT ◆ 認証證書 ◆